

Operator: Validation Manager Vessel: Warehouse  
Process: Validation Product: Pharma  
Session Start: 22-11-2013 09:14:03 Time Zone: UTC offset 01:00:00  
Session Stop: 22-11-2013 09:14:12  
Session Name: Cold Store Validation  
Session Text:



## Limit Report

Name: Cold Storage test  
Description: Limit Report on temperature stability in refrigerator

### Input parameters

Criteria: Passed when  $3,00\text{ }^{\circ}\text{C} < \text{Value} < 5,00\text{ }^{\circ}\text{C}$   
Triggering : Single, Temperature  
Data Series: LC 01, LA 02, LA 03

### Range

Time: 25-11-2013 16:52:40 to 26-11-2013 08:02:10

### Triggering Interval

from	to
25-11-2013 16:52:40	25-11-2013 17:31:50
25-11-2013 17:32:20	25-11-2013 17:33:00
25-11-2013 17:33:20	26-11-2013 08:02:10

Summary Time: **15:08:40**