

Operator: Validation Manager Vessel: Warehouse
Process: Validation Product: Pharma
Session Start: 22-11-2013 09:14:03 Time Zone: UTC offset 01:00:00
Session Stop: 22-11-2013 09:14:12
Session Name: Cold Store Validation
Session Text:



Limit Report

Name: Cold Storage test
Description: Limit Report on temperature stability in refrigerator

Input parameters

Criteria: Passed when $3,00\text{ }^{\circ}\text{C} < \text{Value} < 5,00\text{ }^{\circ}\text{C}$
Triggering : Single, Temperature
Data Series: LC 01, LA 02, LA 03

Range

Time: 25-11-2013 16:52:40 to 26-11-2013 08:02:10

Triggering Interval

| from | to |
|---------------------|---------------------|
| 25-11-2013 16:52:40 | 25-11-2013 17:31:50 |
| 25-11-2013 17:32:20 | 25-11-2013 17:33:00 |
| 25-11-2013 17:33:20 | 26-11-2013 08:02:10 |

Summary Time: **15:08:40**